

The device

## **OXYVAP Modular intermittent flow**

a product of
OXYCOM FRESH AIR BV
Kaagstraat 31
8102 GZ Raalte
The Netherlands

conforms the hygiene requirements of the guidelines VDI 6022 sheet 1 (July 2011) Ventilation and indoor-air quality; Hygiene requirements for ventilation and air-condtioning systems and units

The conformity inspection was passed by test units installed at OXYCOM FRESH AIR BV in Raalte and by sample sets of the local production. Additionally Installation and User Instructions have been checked. Audit period: July 2015—January 2017 with interruptions. The test parameters and results are available on the test report 5291p1\_15.362 of 16th January 2107.

This certificate also attests the conformity to the hygiene requirements of VDI 3803 (February 2010) and DIN EN 13779 (September 2007) at the time of inspection. The certificate is valid for identical devices until December 2017, subject to any changes to the design or materials used.

SYNLAB
Umweltinstitut GmbH
Standort Essen

Frillendorfer Straße 154, 45139 Essen Tel. 0201-20187-0, Fax 0201-20187-11

Essen, 16th January 2017

Hans Joachim Oldenburg
Location Manager Hygiene Institute Essen

